

**A**

Approved kit

Before starting, make sure your equipment meets all legal safety standards (BS EN61243-3).

**L**

Lock out

Identify the point of isolation – lock it off and place warning tags onto the equipment.

**I**

Initial prove

Test your Voltage Indicator (VI) against the proving unit to make sure it is working properly.

**V**

Voltage test

Use your VI to confirm dangerous voltage levels are not in the circuit you are about to work on.

**E**

Ensure

Prove and re-test the VI against the proving unit to ensure it is functioning before working on the circuit.

MARTINDALE ELECTRIC

Keeping You Safe



**A.L.I.V.E – our 5 fail-proof
steps to safe isolation**

martindale-electric.co.uk