


Understanding installation categories

Stay safe and match your equipment to the test location



CAT Ratings

BS EN61010-1 Installation Categories (CAT ratings) define the risks from hazardous transient impulses and potentially lethal short circuit currents on the mains supply system based on where you are working.


Voltage Ratings

Test equipment used for measuring mains circuits will have a CAT rating to show where it can be used. Each category has a voltage rating to show the maximum safe phase to earth system voltage, normally 50V, 100V, 150V, 300V, 600V or 1000V.

Stay safe - match your test equipment safety rating to the installation category

- **CAT II** socket outlets & similar points of mains installation
- **CAT III** distribution part of the building's mains installation
- **CAT IV** supply side source of the building's mains installation

Testers, leads and accessories all need safety ratings equivalent to, or higher than the installation category and voltage rating for use at the specified area in the installation to be safe.



Trusted since 1928

www.martindale-electric.co.uk
+44 (0)1923 441717
sales@martindale-electric.co.uk

MARTINDALE
ELECTRIC
Keeping You Safe